

Calculation of benefit of replacing IE3 motor with IE4+ motor (75 kW, 36000 rpm) for USA

1. Price of 1 kWh of active power in USA in \$: $Ca_{usa} = 0.15$ \$/kWh.
2. Duration of motor operation in hours per year (8 hours per day, 288 days per year): $t_{work} = 2304$ hours.
3. Motor efficiency of IE4+: $\eta_{ie4} = 0.96$.
4. Standard motor efficiency of IE3: $\eta_{ie3} = 0.947$.
5. Active power consumption by IE4+ and IE3 motors:

$$Pa_{ie4} = \frac{P_{2n}}{\eta_{ie4}} t_{work} = \frac{75}{0.96} \cdot 2304 = 179967 \text{ kWh,}$$

$$Pa_{ie3} = \frac{P_{2n}}{\eta_{ie3}} t_{work} = \frac{75}{0.947} \cdot 2304 = 182471 \text{ kWh.}$$

6. Payment for consumed active power by IE4+ and IE3 motors:

$$pay_{ie4} = Pa_{ie4} \cdot Ca_{usa} = 26995 \text{ \$,}$$

$$pay_{ie3} = Pa_{ie3} \cdot Ca_{usa} = 27371 \text{ \$.}$$

7. Benefit per year due to increased efficiency

$$E_{act} = pay_{ie3} - pay_{ie4} = 376 \text{ \$.}$$

8. Power factor of the motor IE4+: $\cos(\varphi) = 0.934$.
9. Power factor of an average IE3 motor: $\cos(\varphi)_{ie3} = 0.87$.
10. Payment for consumed reactive power by IE4+ and IE3 motors:

$$payr_{ie4} = Ca_{usa} \left(\frac{0.9}{\cos(\varphi)} \cdot Pa_{ie4} - Pa_{ie4} \right) = 0 \text{ \$,}$$

$$payr_{ie3} = Ca_{usa} \left(\frac{0.9}{\cos(\varphi)_{ie3}} \cdot Pa_{ie3} - Pa_{ie3} \right) = 944 \text{ \$.$$

11. Benefit per year due to increased power factor:

$$E_{react} = payr_{ie3} - payr_{ie4} = 944 \text{ \$.$$

12. Benefits per year due to increased efficiency and increased power factor:

$$E_{act} = 376 \text{ \$,} \quad E_{react} = 944 \text{ \$.$$

13. Total benefit per year due to replacement of an average IE3 motor with an IE4+ motor:

$$E_{one_year} = E_{act} + E_{react} = 1320 \text{ \$.$$